

North Iowa Community Action  
 Box 1627  
 Mason City, Iowa 50402

**A-B**  
 not filled out

**WEATHERIZATION Natural Gas FURNACE REPLACEMENT BID SHEET**

DATE:

TIME:

TO:

PHONE :

FAX:

FROM: Bart Pals  
 Weatherization Coordinator

PHONE: 641-424-6453  
 FAX : 641-424-0636

RE: Furnace replacement bid

OWNER:

HOUSE VOLUME:  
 HOUSE SQ FEET:

PHONE:  
 PAGES: 2

BTU OUTPUT REQUIREMENT:

MESSAGE: CONTACT OWNER FOR ACCESS. Please fax your bid to 641-424-0636

Furnace brands accepted: American Standard, Amana, Armstrong Aire Ease, Bryant, Carrier, Coleman, Ducane, Frigidaire, Goodman, Heil, Lennox, Luxaire, Nordyne, Olsen Technology, Payne, Rheem, Ruud, Tempstar, Trane, Williamson, and York

**ALL BIDDERS TO PROVIDE MANUFACTURER'S SPECIFICATION SHEETS FOR FURNACE WITH BID SHEET! North Iowa Community Action reserves the right to refuse any or all bids.**

**BID DUE: @ 3 PM.**

**PROPOSED EQUIPMENT**

Item	Eff Rating	BTU Output	Brand and Model #	Price	Full Warranty Period
Install 92+% (minimum) hi-efficiency two (2) pipe system Natural Gas furnace complete with necessary electrical work, gas piping, venting, and duct work as required by current City Code and the Uniform Mechanical Code Requirements: 1. Furnace must be a brand name listed above 2. <b><u>Bid includes replacing thermostat and installing new return drop, one case of filters and a fused switch within 2' of furnace.</u></b> 3. <b><u>Return drop must have a filter rack with a tight door and it must be accessible from outside the furnace.</u></b> 4. Remove, demolish, and dispose of existing furnace.					
<b>TOTAL</b>					

\_\_\_\_\_  
 Heating Contractor's Signature

\_\_\_\_\_  
 Date

1. Af ✓  
1-22-09

North Iowa Community Action  
Box 1627  
Mason City, Ia. 50402

filled out

# WEATHERIZATION NATURAL GAS FURNACE REPLACEMENT BID SHEET

DATE: 7-22-09

TIME: 8:00am

TO: DAN'S PLBG AND HTG  
453 10<sup>TH</sup> AVE NE  
HAMPTON

PHONE: 641-456-3638  
FAX: 641-847-2279

FROM: Bart Pals  
Weatherization Coordinator

PHONE: 641-424-6453  
FAX: 641-424-0636

RE: Furnace replacement bid with existing Central Air

OWNER: ELIZABETH BUSS  
305 SARASOTA  
NEW HARTFORD

HOUSE VOLUME: 18720

HOUSE SQUARE FEET: 1376

PHONE: 319-983-2301

BTU OUTPUT REQUIREMENT: 60,000

NOTE-REPLACE COPPER LINE TO SPACE HEATER-MAY NEED ADDITIONAL DUCTWORK

PAGES: 2

MESSAGE: CONTACT OWNER FOR ACCESS. Please fax your bid to 641-424-0636

Furnace brands accepted: Amana, American Standard, Armstrong Aire Ease, Bryant, Carrier, Coleman, Ducane, Frigidaire, Goodman, Heil, Lennox, Luxaire, Nordyne, Olsen Technology, Payne, Rheem, Ruud, Tempstar, Trane, Williamson, and York

**ALL BIDDERS TO PROVIDE MANUFACTURER'S SPECIFICATION SHEETS FOR FURNACE WITH BID SHEET! North Iowa Community Action reserves the right to refuse any or all bids.**

**BID DUE: 8-10-09 @ 3:00pm**

### PROPOSED EQUIPMENT

Item	Eff Rating	BTU Output	Brand and Model #	Price	Full Warranty Period
Install 92+% (minimum) hi-efficiency two (2) pipe system natural gas furnace complete with necessary electrical work, gas piping, venting, and duct work as required by current City Code and the Uniform Mechanical Code Requirements: 1. Furnace must be a brand name listed above 2. <u>Bid includes replacing thermostat and installing new return drop, one case of filters, and a fused switch within 2' of the furnace.</u> 3. <u>Return drop must have a filter rack with a tight door and it must be accessible from outside the furnace.</u> 4. Remove, demolish, and dispose of existing furnace. 5. <u>Clean "A" coil, drain pan and drain hole. Provide a 6 inch X 8 inch cleaning access panel near bottom of "A" coil with the lowest edge of clean out to be at least 1/4 inch higher than the top of the condensate drain hole.</u>					
<b>TOTAL</b>					

\_\_\_\_\_  
Heating Contractor's Signature

\_\_\_\_\_  
Date